

ASSEMBLY: BOOSTER & FEED HYDRANT 100mm DUAL

PRODUCT CODE

ABFH100

APPROVALS

PIPE: AS 1074 Hot Dipped Gal.
 BOOSTER: AS 2419.3 (Approved)
 SWING CHECK VALVE: UL/FM Listed
 HYDRANT VALVE: AS 2419.2
 BUTTERFLY VALVE: UL/FM Listed
 COUPLINGS: UL/FM Listed

INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

BRIGADE CONNECTIONS

All Australian Fire
 Authorities Available

WORKING PRESSURE

COUPLINGS: 2068 kPa
 BOOSTER: 1400 kPa
 SWING CHECK VALVE: 2068 kPa
 HYDRANT VALVE: 1850 kPa
 BUTTERFLY VALVE: 2068 kPa

OPTIONS AVAILABLE

By-pass / meter to suit local water authority requirements.
 Butterfly valve installed under Booster Head where head pressure is greater than 50 kPa.

