

# ASSEMBLY: BOOSTER & FEED HYDRANT 150mm DUAL

## PRODUCT CODE

ABFH150D

## APPROVALS

PIPE: AS 1074 Hot Dipped Gal.  
 BOOSTER: AS 2419.3 (APPROVED)  
 SWING CHECK VALVE: UL/FM Listed  
 HYDRANT VALVE: AS 2419.2  
 BUTTERFLY VALVE: UL/FM Listed  
 COUPLINGS: UL/FM Listed

## INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

## BRIGADE CONNECTIONS

All Australian Fire  
 Authorities Available

## WORKING PRESSURE

COUPLINGS: 2068 kPa  
 BOOSTER: 1400 kPa  
 SWING CHECK VALVE: 2068 kPa  
 HYDRANT VALVE: 1850 kPa  
 BUTTERFLY VALVE: 2068 kPa

## OPTIONS AVAILABLE

Detector check valve c/w by-pass / meter to suit local water authority requirements  
 Butterfly valve installed under Booster Head where head pressure is greater than 50 kpa.

