

ASSEMBLY: BOOSTER & FEED HYDRANT 150mm DUAL c/w SDCV & D.I. FEED

Compliant with AS 2419.1

PRODUCT CODE

ABFH150DSDT

APPROVALS

FEED: RILSAN COATED: AS 4020
PIPE: AS 1074 Hot Dipped Gal.
BOOSTER: AS 2419.3 (APPROVED)
SDCV: UL/FM Approved (WATERMARKED)
HYDRANT VALVE: AS 2419.2
BUTTERFLY VALVE: UL/FM Listed (WATERMARKED)
COUPLINGS: UL/FM Listed

INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

BRIGADE CONNECTIONS

All Australian Fire
Authorities Available

WORKING PRESSURE

COUPLINGS: 2068 kPa
BOOSTER: 1400 kPa
SDCV: 1209 kPa
HYDRANT VALVE: 1850 kPa
BUTTERFLY VALVE: 2068 kPa

OPTIONS AVAILABLE

Wafer check valve (where specified)
By-pass / meter to suit local
water authority requirements.
Butterfly valve installed under
Booster Head where head pressure
is greater than 50 kpa.

