

# ASSEMBLY: BOOSTER & FEED HYDRANT 150mm QUAD c/w SDCV & D.I. FEED

Compliant with AS 2419.1

## PRODUCT CODE

ABFH150SDT

## APPROVALS

FEED & TEE: RILSAN COATED: AS 4020  
PIPE: AS 1074 Hot Dipped Gal.  
BOOSTER: AS 2419.3 (APPROVED)  
SDCV: UL/FM Approved (WATERMARKED)  
HYDRANT VALVE: AS 2419.2  
BUTTERFLY VALVE: UL/FM Listed (WATERMARKED)  
COUPLINGS: UL/FM Listed

## INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

## BRIGADE CONNECTIONS

All Australian Fire Authorities Available

## WORKING PRESSURE

COUPLINGS: 2068 kPa  
BOOSTER: 1400 kPa  
SDCV: 1209 kPa  
HYDRANT VALVE: 1850 kPa  
BUTTERFLY VALVE: 2068 kPa

## OPTIONS AVAILABLE

By-pass / meter to suit local water authority requirements  
Butterfly valve installed under Booster Head where head pressure is greater than 50 kpa.

