



APPROVALS

Pipe: AS 1074 Hot Dipped Gal
 Booster: AS 2419.3 (Approved)
 Swing check valve: UL/FM listed
 Hydrant valve: AS 2419.2
 Butterfly valve: UL/FM listed
 Couplings: UL/FM listed

INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

BRIGADE CONNECTIONS

All Australian fire authorities available

WORKING PRESSURE

Couplings: 2068 kPa
 Booster: 1400 kPa
 Swing check valve: 2068 kPa
 Hydrant valve: 1850 kPa
 Butterfly valve: 2068 kPa

OPTIONS AVAILABLE

By-pass / meter to suit local water authority requirements
 Butterfly valve installed under booster head where head pressure is greater than 50 kPa

Sizes may vary due to supply of product, contact office to confirm

