



**APPROVALS**

Pipe: AS 1074 Hot Dipped Gal  
 Booster: AS 2419.3 (Approved)  
 Swing check valve: UL/FM listed  
 Hydrant valve: AS 2419.2  
 Butterfly valve: UL/FM listed  
 Couplings: UL/FM listed

**INSTALLATION**

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

**BRIGADE CONNECTIONS**

All Australian fire authorities available

**WORKING PRESSURE**

Couplings: 2068 kPa  
 Booster: 1400 kPa  
 Swing check valve: 2068 kPa  
 Hydrant valve: 1850 kPa  
 Butterfly valve: 2068 kPa

**OPTIONS AVAILABLE**

By-pass / meter to suit local water authority requirements  
 Butterfly valve installed under booster head where head pressure is greater than 50 kPa

\*Sizes may vary due to supply of product, contact office to confirm\*

