



APPROVALS

AS 2419.1
 Feed & tee: AS/NZS 4020 Rilsan coated
 Pipe: AS 1074 Hot Dipped Gal
 Booster: AS 2419.3 (Approved)
 SDCV: UL/FM listed (Approved)
 Hydrant valve: AS 2419.2
 Butterfly valve: UL/FM listed (Approved)
 Couplings: UL/FM listed

INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

BRIGADE CONNECTIONS

All Australian fire authorities available

WORKING PRESSURE

Couplings: 2068 kPa
 Booster: 1400 kPa
 SDCV: 1200 kPa
 Hydrant valve: 1850 kPa
 Butterfly valve: 1600 kPa

OPTIONS AVAILABLE

By-pass / meter to suit local water authority requirements
 Butterfly valve installed under booster head where head pressure is greater than 50 kPa

Sizes may vary due to supply of product, contact office to confirm

