



## BOOSTER & FEED HYDRANT 150mm DUAL c/w SDCV & D.I. FEED

PRODUCT CODE: #ABFH150DSDT

### APPROVALS

AS 2419.1

Feed: Rilsan coated AS 4020

Pipe: AS 1074 Hot Dipped Gal

Booster: AS 2419.3 (Approved)

SDCV: UL/FM listed (watermarked)

Hydrant valve: AS 2419.2

Butterfly valve: UL/FM listed (watermarked)

Couplings: UL/FM listed

### INSTALLATION

Connect to service 150mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

### BRIGADE CONNECTIONS

All Australian fire authorities available

### OPTIONS AVAILABLE

Wafer check valve (where specified)

By-pass / meter to suit local water authority requirements

Butterfly valve installed under booster head where head pressure is greater than 50 kPa

### WORKING PRESSURE

Couplings: 2068 kPa

Booster: 1400 kPa

SDCV: 1209 kPa

Hydrant valve: 1850 kPa

Butterfly valve: 2068 kPa

\*All measurements are a guide only - for accurate measurements please contact KlineFire\*

