LKS MARK 111 MAXI50





DIMENSIONS

Diameter: 555mm Depth: 303mm

RECOMMENDATION

Mounting the Isolation Valve at a height of 1060mm will achieve the Hose Reel centre height of 1500mm

If the minimum Isolation Valve height of 900mm is required, the length of the back pipe will need to be extended on site

Radial Clearance of not less than 100mm must be maintained around the Hose Reel Plates and Isolating Valve

INSTALLATION

Drum Centre: 1400 - 2400mm

Isolation Valve Centre: 900 - 1100mm

MATERIAL

Side Plates: CR-F Steel. Signal Red Spacer Pins: Mild Steel. Zinc Plated

Fire Reel Hose: P.V.C 19mm Internal Diameter

Hose Length: 50 Meters

Nozzle: Jet Lever Action. DR Brass Guide Arm: Swivel. Zinc Plated Bracket: Easi-Fit. Galvanized

Inlet Pipe: Galvanized

Barrell Union: F&F. Galvanized

Spindle: DR Brass Waterway: DR Brass

Isolation Valve: DR Brass. 25mm (M&F) #304

Stainless Steel Interlock & Handle

Sizes may vary due to supply of product, contact office to confirm



