



BOOSTER & FEED HYDRANT 150mm DUAL c/w SDCV & D.I. FEED

PRODUCT CODE: ABFH150DSDT

APPROVALS

- AS 2419.1
- Feed: AS/NZS 4020 Rilsan coated
- Pipe: AS 1074 Hot Dipped Gal
- Booster: AS 2419.3 (Approved)
- SDCV: UL/FM listed (Approved))
- Hydrant valve: AS 2419.2
- Butterfly valve: UL/FM listed (Approved)
- Couplings: UL/FM listed

INSTALLATION

Connect to service 100mm above finished ground level with copper x roll groove adaptors or flanges (either supplied)

BRIGADE CONNECTIONS

All Australian fire authorities available

OPTIONS AVAILABLE

- By-pass / meter to suit local water authority requirements
- Butterfly valve installed under booster head where head pressure is greater than 50 kPa

WORKING PRESSURE

- Couplings: 2068 kPa
- Booster: 1400 kPa
- SDCV: 1200 kPa
- Hydrant valve: 1850 kPa
- Butterfly valve: 1600 kPa

Sizes may vary due to supply of product, contact office to confirm

